



CITY OF EL PASO DE ROBLES
"The Pass of the Oaks"

RFP ADDENDUM NO. 2

PROCUREMENT SERVICES
for a
Pre-fabricated Engineered Metal
Building
City of Paso Robles, California

DPW PROJECT NO. 19-15

RFP ADDENDUM ISSUE DATE: NOVEMBER 26, 2019

RFP DUE DATE: DECEMBER 6, 2019, at 5:00 PM

- Trellis at entryway:
 - o Vertical Loading: DL at each corner of the trellis is ~ 1.35 kips. We also recommend the manufacturer include a 20 psf roof Live load over the footprint of the trellis at this point.
 - o Lateral EQ Loading: The seismic weight of trellis to be resisted by the building is ~ 5.4 kips. This weight should be multiplied by appropriate a_p/R_p and I_p values.
- The lateral load of interior walls can be assumed to be 12 PSF for their weight. Only their out of plane seismic load needs to be considered with the appropriate factors.
- Windows, doors, and insulation are not included as deliverables of this RFP.

#