



CITY OF EL PASO DE ROBLES
"The Pass of the Oaks"

BID ADDENDUM NO. 1

Surface Water Treatment Plant GAC Replacement

DPW PROJECT NO. 22-13

BID ADDENDUM ISSUE DATE: May 19, 2022

BID OPENING: May 26, 2022 at 2:00 PM

NOTE: IT IS NECESSARY TO INCLUDE A SIGNED BID ADDENDUM WITH YOUR BID PROPOSAL IN ORDER FOR THE PROPOSAL TO BE DEEMED RESPONSIVE

I acknowledge receipt of this Bid Addendum, which consists of this page only with additional information and clarification. I further acknowledge that the Bid Proposal submitted for this project incorporates the information contained in this Bid Addendum.

Company Name: _____
Signature: _____
Title: _____
Date: _____

Addendum for Technical Specifications – Installation of GAC, soaking, and backwashing (33282.I.6):

Installation, soaking and backwashing of new carbon shall comply with the technical specification, adsorber system manufacturer’s requirements, and the following:

- Soak time shall be no less than 24 hours.
- Each vessel shall be backwashed at a rate necessary to achieve 25% bed expansion (approximately 800 to 900 gpm). Backwashing flow rate shall be gradually increased and decreased. Flushing shall be conducted until flush water produced from each vessel is clear, free of fines and discoloration, and pH is between 7 and 8. Continuous flushing time for each vessel shall be no less than 30 minutes.
- Flush water disposal capacity is limited to approximately 800 gpm, however limited hydraulic storage in onsite EQ basin allows flushing at a higher rate for short durations. Therefore, only one GAC vessel can be backwashed at a time.

###